

Annexure B: Devices and Points (JC Equipment)

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
STATION 1 - AHU 1.1 - DX13 - NAE 9.	NAE 45 - 9	1	46	HVAC
STATION 1 - AHU 1.1 - XT14	NAE 45 - 9	1		HVAC
STATION 1 - AHU 1.1 - XT15	NAE 45 - 9	1		HVAC
STATION 1 - AHU 1.1 - Supply Air Fan - VND-9	NAE 45 - 9	1	3	HVAC
STATION 1 - AHU 1.1 - Spray Pump 1 - VND-10	NAE 45 - 9	1	3	HVAC
STATION 1 - AHU 1.1 - Spray Pump 2 - VND-11	NAE 45 - 9	1	3	HVAC
STATION 1 - AHU 1.1 - Return Air Fan - VND-69	NAE 45 - 9	1	3	HVAC
STATION 1 - AHU 1.2 - DX16 - NAE 9.	NAE 45 - 9	1	32	HVAC
STATION 1 - AHU 1.2 - XT17	NAE 45 - 9	1		HVAC
STATION 1 - AHU 1.2 - Supply Air Fan - VND-12	NAE 45 - 9	1	3	HVAC
STATION 1 - AHU 1.2 - Return Air Fan - VND-71	NAE 45 - 9	1	3	HVAC
STATION 1 - AHU 11E - DX19.	NAE 45 - 9	1	31	HVAC
STATION 1 - AHU 11E - XT20	NAE 45 - 9	1		HVAC
STATION 1 - AHU 11E - XT21 - NAE 9	NAE 45 - 9	1	5	HVAC
STATION 1 - AHU Z13E - DX24 - NAE 9.	NAE 45 - 9	1	32	HVAC
STATION 1 - AHU Z13E - XT25	NAE 45 - 9	1		HVAC
STATION 1 - AHU Z13E - XT47	NAE 45 - 9	1		HVAC
STATION 1 - AHU Z23N - DX22 - HEAT PUMP FITTED TO THIS UNIT - NAE 9.	NAE 45 - 9	1	39	HVAC
STATION 1 - AHU Z23N - XT23	NAE 45 - 9	1		HVAC
STATION 1 - AHU Z23N - XT46	NAE 45 - 9	1		HVAC
STATION 1 - BOILER - DX61 - NAE 9.	NAE 45 - 9	1	29	HVAC
STATION 1 - BOILER - XT62	NAE 45 - 9	1		HVAC
STATION 1 - RETURN AIR FANS - XT66.	NAE 45 - 9	1	4	HVAC
STATION 2 - RETURN AIR FANS - XT67	NAE 45 - 9	1	4	HVAC
STATION 2 - RETURN AIR FANS - XT68	NAE 45 - 9	1	2	HVAC
STATION 2 - AHU 2.1 - DX28 - NAE 9	NAE 45 - 9	1	51	HVAC
STATION 2 - AHU 2.1 - XT29	NAE 45 - 9	1		HVAC
STATION 2 - AHU 2.1 - XT30	NAE 45 - 9	1		HVAC
STATION 2 - AHU 2.1 - Supply Air Fan - VND-48	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU 2.1 - Spray Pump 1 - VND-53	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU 2.1 - Spray Pump 2 - VND-54	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU 2.1 - Return Air Fan - VND-72	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU 2.2 - DX31 - NAE 9	NAE 45 - 9	1	32	HVAC
STATION 2 - AHU 2.2 - XT32	NAE 45 - 9	1		HVAC
STATION 2 - AHU 2.2 - Supply Air Fan - VND-33	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU 2.2 - Return Air Fan - VND-73	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU 2.3 - DX34 - NAE 9	NAE 45 - 9	1	32	HVAC
STATION 2 - AHU 2.3 - XT35	NAE 45 - 9	1		HVAC
STATION 2 - AHU 2.3 - Supply Air Fan - VND-63	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU 2.3 - Return Air Fan - VND-74	NAE 45 - 9	1	3	HVAC
STATION 2 - AHU Z22W - DX36 - NAE 9	NAE 45 - 9	1	37	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
STATION 2 - AHU Z22W - XT37	NAE 45 - 9	1		HVAC
STATION 2 - AHU Z22W - XT38	NAE 45 - 9	1		HVAC
STATION 2 - CHILLER PLANT - DX39 - NAE 9	NAE 45 - 9	1	49	HVAC
STATION 2 - CHILLER PLANT - XT40	NAE 45 - 9	1		HVAC
STATION 2 - CHILLER PLANT - XT41	NAE 45 - 9	1		HVAC
STATION 2 - CHILLER PLANT - SEC CHW PUMP 1 - VND-55	NAE 45 - 9	1	3	HVAC
STATION 2 - CHILLER PLANT - SEC CHW PUMP 2 - VND-56	NAE 45 - 9	1	3	HVAC
STATION 2 - COOLING TOWERS - DX43 - NAE 9	NAE 45 - 9	1	46	HVAC
STATION 2 - COOLING TOWERS - XT44	NAE 45 - 9	1		HVAC
STATION 2 - COOLING TOWERS - XT45	NAE 45 - 9	1		HVAC
STATION 2 - COOLING TOWER 1 - Fan - VND-57	NAE 45 - 9	1	3	HVAC
STATION 2 - COOLING TOWER 2 - Fan - VND-58	NAE 45 - 9	1	3	HVAC
STATION 3 - AHU 3.1 - DX10 - NAE 10	NAE 45 - 10	1	53	HVAC
STATION 3 - AHU 3.1 - XT11	NAE 45 - 10	1		HVAC
STATION 3 - AHU 3.1 - XT12	NAE 45 - 10	1		HVAC
STATION 3 - AHU 3.1 - XT33	NAE 45 - 10	1		HVAC
STATION 3 - AHU 3.1 - XT67	NAE 45 - 10	1		HVAC
STATION 3 - AHU 3.1 - Supply Air Fan - VND-13	NAE 45 - 10	1	3	HVAC
STATION 3 - AHU 3.1 - Spray Pump 1 - VND-14	NAE 45 - 10	1	3	HVAC
STATION 3 - AHU 3.1 - Spray Pump 2 - VND-15	NAE 45 - 10	1	3	HVAC
AUDITORIUM ROOF - AHU - DX22 - NAE 10	NAE 45 - 10	1	64	HVAC
AUDITORIUM ROOF - AHU - XT23	NAE 45 - 10	1		HVAC
AUDITORIUM ROOF - AHU - XT24	NAE 45 - 10	1		HVAC
AUDITORIUM ROOF - AHU - XT26	NAE 45 - 10	1		HVAC
AUDITORIUM LEVEL 1 G/F - AHU - DX20 - NAE 10	NAE 45 - 10	1	43	HVAC
AUDITORIUM LEVEL 1 G/F - AHU - XT21	NAE 45 - 10	1		HVAC
AUDITORIUM LEVEL 1 G/F AHU - XT25	NAE 45 - 10	1		HVAC
A BLOCK HT/LT MONITORING - DX16 - NAE 10	NAE 45 - 10	1	37	Power
A BLOCK HT/LT MONITORING - XT17	NAE 45 - 10	1		Power
A BLOCK HT/LT MONITORING - XT18	NAE 45 - 10	1		Power
A BLOCK - LEVEL 1 - HT INCOMER POWER MONITORING - VND-19	NAE 45 - 10	1	17	Power
A BLOCK - LEVEL 1 - LT INCOMER - TRANSFORMER 1 - POWER MONITORING - VND-27	NAE 45 - 10	1	17	Power
A BLOCK - LEVEL 1 - LT INCOMER - TRANSFORMER 2 - POWER MONITORING - VND-28	NAE 45 - 10	1	17	Power
A BLOCK - LEVEL 1 - LT INCOMER - GENERATOR 2 - POWER MONITORING - VND-29	NAE 45 - 10	1	17	Power
A BLOCK - LEVEL 1 - LT INCOMER - CAFETERIA - POWER MONITORING - VND-30	NAE 45 - 10	1	17	Power
A BLOCK - LEVEL 1 - LT INCOMER - AUDITORIUM - POWER MONITORING - VND-31	NAE 45 - 10	1	17	Power
A BLOCK - LEVEL 1 - EAST - Diffuser 1	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - EAST - Diffuser 2	NAE 35 - 3	1	8	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
A BLOCK - LEVEL 1 - EAST - Diffuser 3	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - EAST - Diffuser 4	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - EAST - Diffuser 5	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Fynbos Meeting Room 102	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Gardenia Meeting Room 103	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Palesa Meeting Room 104	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Fuschia Meeting Room 105	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Waiting Room 106	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Client Centre 107	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Dzuvhva Meeting Room 108	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Protea Meeting Room 109	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Entrance	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Reception	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Kitchen	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 1 - Diffuser - Disa Meeting Room 113	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 1	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 2	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 3	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 4	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 5	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 6	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 7	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 8	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 9	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 10	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 11	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 12	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 13	NAE 35 - 3	1	8	HVAC
A BLOCK - LEVEL 2 - EAST - Diffuser 14	NAE 35 - 3	1	8	HVAC
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Block B & C Lvl 1 - MIG-46	NAE 45 - 10	1	16	Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Zone - MIG-47	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 1 - MIG-48	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 2 - MIG-49	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 3 - MIG-50	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 4 - MIG-51	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 2 - Block D,E & C Lvl 2&3 - MIG-40	NAE 45 - 10	1	16	Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 2 - Zone - MIG-41	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 2 - Loop 1 - MIG-42	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 2 - Loop 2 - MIG-43	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 2 - Loop 3 - MIG-44	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 2 - Loop 4 - MIG-45	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Block A - MIG-52	NAE 45 - 10	1	16	Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Zone - MIG-53	NAE 45 - 10	1		Fire

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 1 - MIG-54	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 2 - MIG-55	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 3 - MIG-56	NAE 45 - 10	1		Fire
A BLOCK - CONTROL ROOM - FIRE DETECTION PANEL 1 - Loop 4 - MIG-57	NAE 45 - 10	1		Fire
B BLOCK - EXECUTIVE BOARDROOM AHU - DX6 - NAE 9	NAE 45 - 9	1	30	HVAC
B BLOCK - EXECUTIVE BOARDROOM AHU - XT7	NAE 45 - 9	1		HVAC
B BLOCK - LEVEL 1 - WEST - PRD CONTROL - FX07	NAE 35 - 2	1	3	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 1	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 2	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 3	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 4	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 5	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 6	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 7	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 8	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 9	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 10	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 11	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 12	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 13	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 14	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - WEST - DIFFUSER 15	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - PRD CONTROL - FX07	NAE 35 - 2	1	3	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 1	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 2	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 3	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 4	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 5	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 6	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 7	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 8	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 9	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 10	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 11	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 12	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 13	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 14	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 15	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 16	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 17	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 18	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 19	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 20	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 21	NAE 35 - 2	1	8	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
B BLOCK - LEVEL 2 - WEST - DIFFUSER 22	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 2 - WEST - DIFFUSER 23	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - PRD CONTROL - FX07	NAE 35 - 2	1	3	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 1	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 2	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 3	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 4	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 5	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 6	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 7	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 8	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 9	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 10	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 11	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 12	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 13	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 14	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 15	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 3 - WEST - DIFFUSER 16	NAE 35 - 2	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - PRD CONTROL - FX07	NAE 35 - 2	1	3	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 1	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 2	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 3	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 4	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 5	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 6	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 7	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 8	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 1 - EAST - DIFFUSER 9	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - PRD CONTROL - FX07	NAE 35 - 3	1	3	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 1	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 2	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 3	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 4	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 5	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 6	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 7	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 8	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 2 - EAST - DIFFUSER 15 - Info Centre Print Room	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 3 - EAST - PRD CONTROL - FX07	NAE 35 - 3	1	3	HVAC
B BLOCK - LEVEL 3 - EAST - DIFFUSER 1	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 3 - EAST - DIFFUSER 2	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 3 - EAST - DIFFUSER 3	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 3 - EAST - DIFFUSER 4	NAE 35 - 3	1	8	HVAC
B BLOCK - LEVEL 3 - EAST - Kgalagadi 1	NAE 35 - 3	1	8	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
B BLOCK - LEVEL 3 - EAST - Kgalagadi 2	NAE 35 - 3	1	8	HVAC
C BLOCK - LEVEL 1 - EAST/WEST - PRD CONTROL - FX07	NAE 35 - 4	1	3	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 1	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 2	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 3	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 4	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 5	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 6	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 7	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 8	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 9	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 1 - DIFFUSER 10	NAE 35 - 5	1	8	HVAC
C BLOCK - LEVEL 2 - EAST/WEST - PRD CONTROL - FX07	NAE 35 - 6	1	3	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 1	NAE 35 - 7	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 2	NAE 35 - 8	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 3	NAE 35 - 9	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 4	NAE 35 - 10	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 5	NAE 35 - 11	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 6	NAE 35 - 12	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 7	NAE 35 - 13	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 8	NAE 35 - 14	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 9	NAE 35 - 15	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 10	NAE 35 - 16	1	8	HVAC
C BLOCK - LEVEL 2 - DIFFUSER 11	NAE 35 - 17	1	8	HVAC
C BLOCK - LEVEL 3 - EAST/WEST - PRD CONTROL - FX07	NAE 35 - 18	1	3	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 1	NAE 35 - 19	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 2	NAE 35 - 20	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 3	NAE 35 - 21	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 4	NAE 35 - 22	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 5	NAE 35 - 23	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 6	NAE 35 - 24	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 7	NAE 35 - 25	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 8	NAE 35 - 26	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 9	NAE 35 - 27	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 10	NAE 35 - 4	1	8	HVAC
C BLOCK - LEVEL 3 - DIFFUSER 11	NAE 35 - 4	1	8	HVAC
D BLOCK ROOF - AHU's E1/W1 - DX3	NAE 45 - 9	1	50	HVAC
D BLOCK ROOF - AHU's D/E - XT58	NAE 45 - 9	1		HVAC
D BLOCK ROOF - AHU's E1/W1 - Return Air Fan - VND-8	NAE 45 - 9	1	3	HVAC
D BLOCK ROOF - AHU's E1 - Supply Air Fan - VND-64	NAE 45 - 9	1	3	HVAC
D BLOCK ROOF - AHU's W1 - Supply Air Fan - VND-65	NAE 45 - 9	1	3	HVAC
D BLOCK - DIESEL/FIRE MONITORING - DX27	NAE 45 - 9	1	12	Fire

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
D BLOCK - DIESEL/FIRE MONITORING - XT42	NAE 45 - 9	1		Fire
D BLOCK - BASEMENT VENT FANS - XT18	NAE 45 - 9	1	11	HVAC
D BLOCK - BASEMENT VENT FANS - XT26	NAE 45 - 9	1	6	HVAC
D BLOCK - BASEMENT VENT FANS - XT60	NAE 45 - 9	1	6	HVAC
D BLOCK - LEVEL 0 - HT MAIN INCOMER POWER MONITORING - VND-50	NAE 45 - 9	1	17	Power
D BLOCK - LEVEL 0 - LT BUILDING LOAD MONITORING - VND-51	NAE 45 - 9	1	17	Power
D BLOCK - LEVEL 0 - LT HVAC POWER MONITORING - VND-52	NAE 45 - 9	1	17	Power
D BLOCK ROOF - HEAT PUMP E - Indoor 0_8 - Device-190008	NAE 45 - 10	1	19	HVAC
D BLOCK ROOF - HEAT PUMP E - Indoor 0_9 - Device-190009	NAE 45 - 10	1	19	HVAC
D BLOCK ROOF - HEAT PUMP E - Indoor 0_10 - Device-190010	NAE 45 - 10	1	19	HVAC
D BLOCK ROOF - HEAT PUMP E - Indoor 0_11 - Device-190011	NAE 45 - 10	1	19	HVAC
D BLOCK ROOF - HEAT PUMP W - Indoor 0_12 - Device-190012	NAE 45 - 10	1	19	HVAC
D BLOCK ROOF - HEAT PUMP W - Indoor 0_13 - Device-190013	NAE 45 - 10	1	19	HVAC
D BLOCK ROOF - HEAT PUMP W - Indoor 0_14 - Device-190014	NAE 45 - 10	1	19	HVAC
D BLOCK ROOF - HEAT PUMP W - Indoor 0_15 - Device-190015	NAE 45 - 10	1	19	HVAC
D BLOCK - LEVEL 1 - EAST/WEST - PRD CONTROL - FX07	NAE 35 - 5	1	3	HVAC
D BLOCK - LEVEL 1 - Diffuser 1	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 2	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 3	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 4	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 5	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 6	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 7	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 8	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 9	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 10	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 11	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 12	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 13	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 14	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 15	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 1 - Diffuser 16	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - EAST/WEST - PRD CONTROL - FX07	NAE 35 - 5	1	3	HVAC
D BLOCK - LEVEL 2 - Diffuser 1	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 2	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 3	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 4	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 5	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 6	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 7	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 8	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 9	NAE 35 - 5	1	8	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
D BLOCK - LEVEL 2 - Diffuser 10	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 11	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 12	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 13	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 14	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 2 - Diffuser 15	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - EAST/WEST - PRD CONTROL - FX07	NAE 35 - 5	1	3	HVAC
D BLOCK - LEVEL 3 - Diffuser 1	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 2	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 3	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 4	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 5	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 6	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 7	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 8	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 9	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 10	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 11	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 12	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 13	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 14	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 15	NAE 35 - 5	1	8	HVAC
D BLOCK - LEVEL 3 - Diffuser 16	NAE 35 - 5	1	8	HVAC
E BLOCK ROOF - AHU's E2/W2 - DX1	NAE 45 - 9	1	41	HVAC
E BLOCK ROOF - AHU's E2/W2 - XT70	NAE 45 - 9	1		HVAC
E BLOCK ROOF - AHU's E2 - Supply Air Fan - VND-2	NAE 45 - 9	1	3	HVAC
E BLOCK ROOF - AHU's W2 - Supply Air Fan - VND-4	NAE 45 - 9	1	3	HVAC
E BLOCK ROOF - AHU's E2/W2 - Return Air Fan - VND-5	NAE 45 - 9	1	3	HVAC
E BLOCK ROOF - HEAT PUMP E - Indoor 0_0 - Device-190000	NAE 45 - 10	1	19	HVAC
E BLOCK ROOF - HEAT PUMP E - Indoor 0_1 - Device-190001	NAE 45 - 10	1	19	HVAC
E BLOCK ROOF - HEAT PUMP E - Indoor 0_2 - Device-190002	NAE 45 - 10	1	19	HVAC
E BLOCK ROOF - HEAT PUMP E - Indoor 0_3 - Device-190003	NAE 45 - 10	1	19	HVAC
E BLOCK ROOF - HEAT PUMP W - Indoor 0_4 - Device-190004	NAE 45 - 10	1	19	HVAC
E BLOCK ROOF - HEAT PUMP W - Indoor 0_5 - Device-190005	NAE 45 - 10	1	19	HVAC
E BLOCK ROOF - HEAT PUMP W - Indoor 0_6 - Device-190006	NAE 45 - 10	1	19	HVAC
E BLOCK ROOF - HEAT PUMP W - Indoor 0_7 - Device-190007	NAE 45 - 10	1	19	HVAC
E BLOCK - LEVEL 1 - PRD CONTROL - FX07	NAE 35 - 6	1	3	HVAC
E BLOCK - LEVEL 1 - Diffuser 1	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 2	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 3	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 4	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 5	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 6	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 7	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 8	NAE 35 - 6	1	8	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
E BLOCK - LEVEL 1 - Diffuser 9	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 10	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 11	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 12	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 13	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 14	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 15	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 1 - Diffuser 16	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - PRD CONTROL - FX07	NAE 35 - 6	1	3	HVAC
E BLOCK - LEVEL 2 - Diffuser 1	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 2	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 3	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 4	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 5	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 6	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 7	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 8	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 9	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 10	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 11	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 12	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 13	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 14	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 15	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 2 - Diffuser 16	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - PRD CONTROL - FX07	NAE 35 - 6	1	3	HVAC
E BLOCK - LEVEL 3 - Diffuser 1	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 2	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 3	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 4	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 5	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 6	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 7	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 8	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 9	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 10	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 11	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 12	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 13	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 14	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 15	NAE 35 - 6	1	8	HVAC
E BLOCK - LEVEL 3 - Diffuser 16	NAE 35 - 6	1	8	HVAC
IDC 1 - BLOCK D - Diffuser - Room 1	NAE 35 - 3	1	8	HVAC
IDC 1 - BLOCK D - Diffuser - Room 2	NAE 35 - 3	1	8	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
IDC 1 - BLOCK D - Diffuser - Room 3	NAE 35 - 3	1	8	HVAC
IDC 1 - BLOCK D - Diffuser - Room 4	NAE 35 - 3	1	8	HVAC
IDC 1 - BLOCK D - Diffuser - Room 5	NAE 35 - 3	1	8	HVAC
IDC 2 - AHU 3N - 5104		1	38	HVAC
IDC 2 - LEVEL 3 - AHU 3 NORTH - Supply Air Fan - VND-117	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 3S - 5103		1	38	HVAC
IDC 2 - LEVEL 3 - AHU 3 SOUTH - Supply Air Fan - VND-116	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 3E - 5101		1	38	HVAC
IDC 2 - LEVEL 3 - AHU 3 EAST - Supply Air Fan - VND-100	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 3W - 5099		1	38	HVAC
IDC 2 - LEVEL 3 - AHU 3 WEST - Supply Air Fan - VND-102	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 2E - 5097		1	38	HVAC
IDC 2 - LEVEL 2 - AHU 2 EAST - Supply Air Fan - VND-96	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 2W - 5095		1	38	HVAC
IDC 2 - LEVEL 2 - AHU 2 WEST - Supply Air Fan - VND-98	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 2N - 5107		1	38	HVAC
IDC 2 - LEVEL 2 - AHU 2 NORTH - Supply Air Fan - VND-108	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 2S - 5105		1	38	HVAC
IDC 2 - LEVEL 2 - AHU 2 SOUTH - Supply Air Fan - VND-106	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 1N - 5111		1	38	HVAC
IDC 2 - LEVEL 1 - AHU 1 NORTH - Supply Air Fan - VND-112	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 1S - 5109		1	38	HVAC
IDC 2 - LEVEL 1 - AHU 1 SOUTH - Supply Air Fan - VND-110	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 1E - 5093		1	38	HVAC
IDC 2 - LEVEL 1 - AHU 1 EAST - Supply Air Fan - VND-92	NAE 35 - 8	1	3	HVAC
IDC 2 - AHU 1W - 5091		1	38	HVAC
IDC 2 - LEVEL 1 - AHU 1 WEST - Supply Air Fan - VND-94	NAE 35 - 8	1	3	HVAC
IDC 2 - BASEMENT CHILLER PLANT & UPS - 5089		1	41	HVAC
IDC 2 - BRIDGE - XT115 - NAE 8	NAE 35 - 8	1	4	
IDC 2 - LEVEL 1 - DIFFUSER 2	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 3	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 4	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 5	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 6	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 7	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 8	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 9	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 10	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 11	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 12	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 13	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 14	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 15	NAE 35 - 7	1	8	HVAC

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
IDC 2 - LEVEL 1 - DIFFUSER 16	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 17	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 18	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 19	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 1 - DIFFUSER 20	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 1	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 2	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 3	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 4	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 5	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 6	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 7	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 8	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 9	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 10	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 11	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 12	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 13	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 2 - DIFFUSER 14	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 1	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 2	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 3	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 4	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 5	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 6	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 7	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 8	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 9	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 10	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 11	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 12	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 13	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 14	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - DIFFUSER 15	NAE 35 - 7	1	8	HVAC
IDC 2 - LEVEL 3 - NETWORK ROOM FX-7	NAE 35 - 7	1	9	HVAC
A BLOCK - BASEMENT - LT INCOMER - TOTAL LOAD - POWER MONITORING - VND-118	NAE 45 - 10	1	17	Power
A BLOCK - BASEMENT - LT HVAC LOAD - POWER MONITORING - VND-119	NAE 45 - 10	1	17	Power
A BLOCK - BASEMENT - LT BUILDING LOAD - POWER MONITORING - VND-120	NAE 45 - 10	1	17	Power
IDC 2 - GYM - HOT WATER TEMPERATURE	NAE 35 - 8	0	1	Domestic Water
IDC 2 - HEAT PUMPS - Mitsubishi-HD-150 - Mitsubishi-H-D150	NAE 45 - 10	1	72	HVAC
A BLOCK - CTRL RM- FIRE DETECTION PANEL 3 - IDC 2 - Reception - MIG-58	NAE 45 - 10	1	16	Fire

<u>Device</u>	<u>NAE</u>	<u>Controllers</u>	<u>Points</u>	
A BLOCK - CTRL RM - FIRE DETECTION PANEL 3 - IDC 2 - Reception - Zone - MIG-59	NAE 45 - 10	1		Fire
A BLOCK - CTRL RM - FIRE DETECTION PANEL 3 - IDC 2 - Reception - Loop 1 - MIG-60	NAE 45 - 10	1		Fire
A BLOCK - CTRL RM - FIRE DETECTION PANEL 3 - IDC 2 - Reception - Loop 2 - MIG-61	NAE 45 - 10	1		Fire
A BLOCK - CTRL RM - FIRE DETECTION PANEL 3 - IDC 2 - Reception - Loop 3 - MIG-62	NAE 45 - 10	1		Fire
A BLOCK - CTRL RM - FIRE DETECTION PANEL 3 - IDC 2 - Reception - Loop 4 - MIG-63	NAE 45 - 10	1		Fire
Total:		472	4453	