

**SUBJECT : BILL OF QUANTITIES**

**BILL NO 9 : FIRE SEALING**

Item	Description	Unit	Quantity	Tariff	Amount
	All in accordance with the drawings and specification  Price given below shall be nett cost of materials supplied and installed on site and shall: a) - exclude profit, overheads, financing, insurance and guarantee costs b) - exclude engineering and management costs c) - exclude VAT				
<b>1</b>	<b>Top of wall (2hr) - The gap between the top of wall and the slabs is typically 15mm</b>	m	200		
	<b>Trafficable seals (2hr) - Typically in electrical risers</b>				
<b>2</b>	300 x 300	No	16		
<b>3</b>	600 x 600	No	8		
<b>4</b>	1000 x 600	No	8		
	<b>Pipe collars (2hr) - Around sewer and other HDPE piping</b>				
<b>5</b>	dia 200	No	16		
<b>6</b>	dia 300	No	16		
	<b>Wall (2hr) around pipes or cables</b>				
<b>7</b>	Dia 50	No	20		
<b>8</b>	Dia 80	No	8		
<b>9</b>	Dia 110	No	385		
<b>10</b>	Dia 150	No	8		
<b>11</b>	Dia 200	No	158		
<b>12</b>	Dia 300	No	10		
<b>13</b>	Dia 350	No	4		
	<b>Wall (2hr) around AC duct (maximum gap is 100mm), openings sizes are as follow:</b>				
<b>14</b>	1500 x 600	No	6		
<b>15</b>	800 x 800	No	40		
<b>16</b>	600 x 600	No	40		
	<b>Wall (2hr) electrical openings (include coating cables 500mm to either side of opening), opening sizes are as follow:</b>				
<b>17</b>	1350 x 300	No	8		
<b>18</b>	1000 x 300	No	16		
<b>19</b>	500 x 450	No	16		
<b>20</b>	500 x 300	No	32		
<b>21</b>	200 x 200	No	16		
<b>22</b>	<b>Double swing Class B Fire Doors</b>	No	4		
<b>23</b>	<b>Single leaf Class B fire doors</b>	No	4		
<b>TOTAL TRANSFERRED TO "SUMMARY OF TENDER BILLS" ITEM 9</b>					

**SUBJECT : BILL OF QUANTITIES**

**BILL NO 9 : FIRE SEALING**

Item	Description	Unit	Quantity	Tariff	Amount
------	-------------	------	----------	--------	--------